

Net Positive Suction Head (NPSH) Required



Percentages expressed are the percentages of the pump's maximum flow rate:

100%	26' NPSH Required (8 MWC)
75%	10' NPSH Required (3 MWC)
50%	5' NPSH Required (1.5 MWC)
25%	3' NPSH Required (1 MWC)

Example: If the pump is run at 50% of it's maximum volume, 5' of NPSH is required.

